

Certificate

of
Continued Compliance

No: 152350018/AA/01

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **Passive Infrared (PIR) detector**
Trademark: **Optex**
Type designation: **RXC-ST**
Hardware / Software version: **3 / 1.3.0**

Manufacturer: **Optex Co., Ltd.**
Address: **Ogoto Shiga 5-8-12**
City: **520-0101 OTSU**
Country: **Japan**

This certificate is granted to:

Name: **Optex Co., Ltd.**
Address: **Ogoto Shiga 5-8-12**
City: **520-0101 OTSU**
Country: **Japan**

Expiry date: **09 December 2023**

This certificate has THREE Annexes.

Zevenaar, 25 February 2019



Jan Willem Verwoert
Project Manager



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

According to EN 50131-1:2006+A1:2009, this equipment can be applied in installed systems up to and including security grade 2

Factory Location:

Optex (Dongguan) Co. Ltd.

Tianmei, Industrial North Zone, Huangjiang Town

523752 Dongguan

Guangdong

China



Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 181001750-001-Ver. 2.00, 14 February 2019

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- ISO 9001 certificate
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2

November, 2017

Technical features and characteristics

The product includes the following features and characteristics:

Not specified



The product as described in this certificate includes the following type designations:

- Product description: Passive Infrared (PIR) detector
- Trademark: Optex
- Type designation: RXC-ST
- Hardware version: 3
- Software version: 1.3.0