

Certificate

of
Type-Examination

No: 192330023/AA/00

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate.
This certificate relates to an ISO/IEC 17067 scheme type 1a registration.

Product description: **UNii alarm panel**
Trademark: **UNii**
Type designation: **UNii**
Hardware / Software version: **1.8 / 1.1.3**

Manufacturer: **Alphatronics B.V.**
Address: **Boekdrukker 5-7**
City: **3861 SE NIJKERK GLD**
Country: **Netherlands**

This certificate is granted to:

Name: **Alphatronics B.V.**
Address: **Boekdrukker 5-7**
City: **3861 SE NIJKERK GLD**
Country: **Netherlands**

This certificate has THREE Annexes.

Zevenaar, 05 March 2020



Jan Willem Verwoert
Project Manager



Remarks and observations

The following conditions are applicable:

Security grade: 3
Environmental class: II
Equipment class: Fixed
Power supply type: A
ATS class: Ethernet or GSM: SP3
Ethernet (main) and GSM (backup): DP4

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.
Electromagnetic emission and safety aspects are not covered by this certificate.

Documentation lodged for this Certificate of Type-Examination

Test Reports:

- Telefication B.V.: 190500178-001 Ver2.00, 03 March 2020
- Telefication B.V.: 190500178-ENV Ver2.00, 03 March 2020
- Telefication B.V.: 190500178-002-Ver 2.00, 03 March 2020
- Telefication B.V.: 190500178-004 Ver2.00, 03 March 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10	June, 2014
EN 50131-3	March, 2009

Applied Standards

EN 50130-5	June, 2011
EN 50136-1+A1	November, 2018
EN 50131-6	October, 2017
EN 50136-2	August, 2013
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2	May, 2017

The product as described in this certificate includes the following type designations:

- Product description: UNii alarm panel
- Trademark: UNii
- Type designation: UNii
- Hardware version: 1.8
- Software version: 1.1.3