



# Certificate of Conformity 242340008/AA/00



Issued 22-08-2024  
Expiry date 22-08-2027

Replaces  
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 2 registration including yearly product inspection.

Product description: UNii UN-X-PIR/AM PIR anti-mask detector (15m)  
Trademark: UNii  
Type designation: UN-X-PIR/AM  
Software: 1069.4

Placed on the market under the name or trademark of:

Name of the manufacturer: Alphontronics B.V.  
Address: Boekdrukker 5-7  
City: 3861 SE Nijkerk (GLD)  
Country: NL

This certificate is granted to:

Name of the certificate holder: Alphontronics B.V.  
Address: Boekdrukker 5-7  
City: 3861 SE Nijkerk (GLD)  
Country: NL

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



## Remarks and observations

The following conditions are applicable:

Security grade: 3

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

This equipment can be used in combination with bracket UN-X-MB3.

Product inspection location:

Alphatronics B.V.

Boekdrukker 5-7

Nijkerk (GLD)

Nederland

## Documentation lodged for this Certificate of Conformity

### Test Reports:

- Telefication B.V.: P000117865-001-Ver. 1.00, 14 September 2022
- Telefication B.V.: P000263944-001-Ver.1.00, 27 December 2022

### Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2

December, 2021

## Applied Standards

EN 50130-4+A1

October, 2014

EN 50131-1+A1+A2+A3

June, 2020

EN 50130-5

June, 2011

**The product as described in this certificate includes the following type designations**

- Product description: UNii UN-X-PIR/AM PIR anti-mask detector (15m)
- Trademark: UNii
- Type designation: UN-X-PIR/AM
- Hardware version: 0
- Software version: 1069.4