

Certificate 262340014/AA/00



Issued **20-07-2026** Replaces **192330023/AA/00**
Valid until **28-02-2029** Page **1 of 1**

Certificate of Conformity

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 2 registration including yearly product inspection.

Product description: UNii alarm panel
Trademark: UNii
Type designation: UNii
Hardware / software: 1.8 / 2.22.0

Placed on the market under the name or trademark of:

Name of the manufacturer: Alphonics B.V.
Address: Boekdrukker 5-7
City: 3861 SE Nijkerk (GLD)
Country: NL

Wim van Loon
Managing Director Nederland

This Certificate has THREE Annexes.
Disclosure of the certificate is permitted.
The certificate validity can be verified via the following link:
<https://www.kiwa.com/nl/en-nl/markets/fire-safety-and-security/certificates/>



Annex 1 to Certificate of Conformity

262340014/AA/00

Remarks and observations

The following conditions are applicable:

Security grade: 3

Environmental class: II

Equipment class: Fixed

Power supply type: A

ATS class:

Ethernet or GSM: SP3

Ethernet (main) and GSM (backup): DP4

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Electromagnetic emission and safety aspects are not covered by this certificate.

Product inspection location:

Alphatronics B.V.

Boekdrukker 5-7

Nijkerk (GLD)

Nederland

Annex 2 to Certificate of Conformity

262340014/AA/00

Documentation lodged for this Certificate of Conformity

Test Reports:

- Telefication B.V.: 190500178-001 Ver2.00, 03 March 2020
- Telefication B.V.: 190500178-ENV Ver2.00, 03 March 2020
- Telefication B.V.: 190500178-002-Ver 2.00, 28 February 2020
- Telefication B.V.: 190500178-004 Ver2.00, 03 March 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10	June, 2014
EN 50131-3	March, 2009

Applied Standards

EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-6+A1	June, 2021
EN 50136-1+A1	November, 2018
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

Annex 3 to Certificate of Conformity

262340014/AA/00

The product as described in this certificate includes the following type designations

- | | |
|------------------------|------------------|
| - Product description: | UNii alarm panel |
| - Trademark: | UNii |
| - Type designation: | UNii |
| - Hardware version: | 1.8 |
| - Software version: | 2.22.0 |