



Certificate of  
Conformity  
**212340014/AA/00**



Issued 20-07-2021  
Expiry date 20-07-2024

Replaces  
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 2 registration including yearly product inspection.

Product description: Magnetic contact  
Trademark: UNii  
Type designation: UN-WMAG\_SLIM  
Hardware / Software: 01 / 2.0.0

Placed on the market under the name or trademark of:

Name of the manufacturer: Alphontronics B.V.  
Address: Boekdrukker 5-7  
City: 3861 SE NIJKERK GLD  
Country: The Netherlands

This certificate is granted to:

Name of the certificate holder: Alphontronics B.V.  
Address: Boekdrukker 5-7  
City: 3861 SE NIJKERK GLD  
Country: The Netherlands

Ron Scheepers  
Managing director

Telefication B.V.  
Kiwa FSS Products  
Wilmsdorp 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

*This certificate has THREE Annexes.*



## Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Electromagnetic emission and safety aspects are not covered by this certificate.

Product inspection location:

Alphatronics B.V.

Boekdrukker 5-7

NIJKERK GLD

The Netherlands

**Documentation lodged for this Certificate of Conformity**

## Test Reports:

- Hermon Laboratories Ltd.: CROENV\_EN.29859\_Rev1, 18 February 2020
- ANPI asbl: bis-rec-1415-00\_Crow Class II products for SO2\_Hermon Labs, 31 October 2017
- Hermon Laboratories Ltd.: CROIAS\_EN 50131-2-6.36617, 10 March 2020
- Hermon Laboratories Ltd.: CROIAS\_EN 50131-6.36616, 10 March 2020
- Hermon Laboratories Ltd.: CRORAD\_EN.29859\_36617\_EN 50131-5-3\_MAG, 18 February 2020
- Hermon Laboratories Ltd.: CROEMC\_EN.29858\_36617, 18 February 2020

## Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-2-6	September, 2008
EN 50131-5-3	March, 2017

**Applied Standards**

EN 50130-5	June, 2011
EN 50131-6	October, 2017
EN 50131-1+A1+A2	May, 2017
EN 50130-4+A1	October, 2014

The product as described in this certificate includes the following type designations

- Product description: Magnetic contact
- Trademark: UNii
- Type designation: UN-WMAG\_SLIM
- Hardware version: 01
- Software version: 2.0.0